

March 23, 2017

Office of Hopkins County Judge
The Honorable Robert Newsom
Post Office box 288
Sulphur Springs, Texas 75483

Farmers Electric Cooperative Member: Robert Brantley
Service Order Number: 1611001065

Dear Judge Newsom,

Farmers Electric Cooperative, Inc. is requesting permission to re-route existing electrical power distribution facilities *across CR 4707, which is located approximately 1140 feet north of county road 4706, in Hopkins County, Texas.*

Site location map and construction sketches are enclosed. The construction sketch details the proposed work. All road crossing will have a minimum vertical clearance of 22 feet.

If you have any questions, please contact field engineering representative Mark Simpson Office 903-461-2458.

Sincerely,

Mark Simpson

Engineering Assistant

msimpson@farmerselectric.coop

Enclosures


Submitted by:

Tricia Griffin

Field Engineering Coordinator

Office 903-453-0563 Fax **903-453-0663**

tgriffin@farmerselectric.coop



Basemap



Robert Brantley
s/o #1611001065
pole #088085

HOPKINS

County Road 4705

County Road 4706

County Road 4707

Happy Cr.

11

11

© 2013 Google

14.4KV



1140' Feet to CR 4706




1



4 ACSR

Oil top CR 4707

Rock Drive



Proposed House
will be 200A

