



Farmers Electric Cooperative

A Touchstone Energy[®] Cooperative 

301 N. Hillcrest
Sulphur Springs, TX 75482

2000 I-30 E
Greenville, TX 75402

108 W. Marble
Wylie, TX 75098



September 11, 2018

Office of Hopkins County Judge
The Honorable Robert Newsom
Post Office Box 288
Sulphur Springs, TX 75483

Farmers Electric Cooperative Member: Joshua Broeske
Service Order Number: 1809002078

Dear Judge Newsom,

Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution **across County Road 4728, which is located approximately 2044' west from CR 4730 in Hopkins County, Texas.**

Site location map and construction sketches are enclosed. The construction sketch details the proposed work. All road crossing will have a minimum vertical clearance of 22 feet.

If you have any questions, please contact your field engineering representative Tamara Williams at 903-453-0549 office, or 903-513-2903 mobile.

Please send approval back to our engineering group at: EngCC@farmerselectric.coop


Sincerely,

Tamara Williams

Engineering Aide
twilliams@farmerselectric.coop

Enclosures

Submitted by:
Linda Graham
Field Engineering Coordinator
Office: 903-453-0716 Fax: 903-453-0660
lgraham@farmerselectric.coop


Date: 9/24/18

Approved Denied

County Comments: _____


FM 275

CR 4730


HOPKINS

FARMERS ELECTRIC COOP
S/O 1809002078
JOSHUA BROESKE
POLE 059324

CR 4728



14.4KV



Cost Estimate Only, Patrick!

drive

300' span

40amp Fuse

75' slack

Protective Device is OCR

Tree Trimming by Member is Required

EASEMENT

2TPX

1/0 ACSR

1/0 ACSR

250ft

Pole is 1988 and will need to be changed out.

CD 4739